



**OPTIONAL ANNUAL REPORT**

<b>Drinking-Water System Number:</b>	<b>W260092014</b>
<b>Drinking-Water System Name:</b>	Township of Russell Distribution
<b>Drinking-Water System Owner:</b>	Township of Russell
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1 to December 31, 2013

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [<input checked="" type="checkbox"/>] No [ <input type="checkbox"/> ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [<input checked="" type="checkbox"/>] No [ <input type="checkbox"/> ]  <a href="http://www.russell.ca">www.russell.ca</a></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Township of Russell              Public Utilities              851 Route 400 and 717 Notre-Dame St.              Embrun ON K0A 1W1</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input type="text" value="n/a"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ <input type="checkbox"/> ] No [ <input type="checkbox"/> ] n/a</p> <p>Number of Interested Authorities you report to: <input type="text" value="n/a"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ <input type="checkbox"/> ] No [ <input type="checkbox"/> ] n/a</p>
--	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
n/a	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
 Yes [  ] No [  ] n/a



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method \_\_\_\_\_

**Describe your Drinking-Water System**

**Owner and Operating Authority**

The Township of Russell is the Owner and Operating Authority of a Drinking Water System that includes:

- Four storage tanks (three elevated towers and one above ground reservoir);
- A distribution network and its associated appurtenances.

**Water Source**

Treated water is supplied by the City of Ottawa through a connection to its distribution system from Mitch Owens Road and Bank Street to Embrun Reservoir.

**Existing Water Works - Distribution System**

The water system for Township of Russell is currently a Class 2 distribution system and serves approximately 11,000 people,

Treated water is pumped from the City of Ottawa through a 450 mm feeder main to the Embrun Reservoir where chlorine and ammonia are added. From there it is pumped to the Embrun Tower and to the Russell Water tower and then to the Marionville booster pumping station and then pumped to the Marionville tower.

The distribution system consists of PVC and Polyethylene pipes ranging from 25 mm (1 inch) service connections to a 406 mm (16 inch) piping. Piping in the local distribution networks in the communities of Embrun, Russell and Marionville consist largely of 150 mm, 200 mm, 250 mm and 350 mm PVC pipes. The municipal distribution system also contains fire hydrants, standard service connections, gate valves, valve chambers, isolation and interconnection valves, blow-off points, drain valve chambers, and air release chambers.

**Facilities:**

- 450mm diameter connection to Russell Feedermain (from City of Ottawa) at Embrun Reservoir site;
- connection to Russell watermain (toward community of Russell) at Embrun Reservoir site;
- connection to Marionville watermain (replacement of modulating control valve by a pipe section, between Marionville Booster Station and Marionville, on MacDonald Road).
- Embrun Reservoir (re-chlorination facility)

**List all water treatment chemicals used over this reporting period**

Sodium hypochlorite, Ammonium Sulfate



**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

<b>Water meters</b>	<b>\$13,042.20</b>
<b>M&amp;S Fire Hydrants</b>	<b>\$4,247.00</b>
<b>S&amp;R Fire Hydrants</b>	<b>\$5,676.78</b>
<b>Service and Rents</b>	<b>\$50,986.76</b>
<b>Material &amp; Supplies</b>	<b>\$25,345.56</b>
<b>TOTAL</b>	<b>\$99,298.30</b>

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

<b>Incident Date</b>	<b>Parameter</b>	<b>Result</b>	<b>Unit of Measure</b>	<b>Corrective Action</b>	<b>Corrective Action Date</b>
July 8/13	Total Coliform	21	ct/100mL	Resample/retest, flushing	July 12/13
July 16/13	E.Coli	1	ct/100mL	Resample/retest, flushing, BWA	July 18/13
July 16/13	Total Coliform	30	ct/100mL	Resample/retest, flushing, BWA	July 18/13
July 16/13	TC	3	ct/100mL	Resample/retest, flushing	July 17/13

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	<b>Number of Samples</b>	<b>Range of E.Coli Or Fecal Results (min #)-(max #)</b>	<b>Range of Total Coliform Results (min #)-(max #)</b>	<b>Number of HPC Samples</b>	<b>Range of HPC Results (min #)-(max #)</b>
<b>Distribution</b>					
Embrun	187	0-1	0-30	187	0-110
Marionville	115	0	0-3	115	0-51
Russell	167	0	0	167	0-203

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**



	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	1460	0.05 – 0.23
Chlorine - Combined	2284	0.33 – 2.77
Fluoride (If the DWS provides fluoridation)	n/a	

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is not milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
O.Reg 399/07 Schedule 15.1	Alkalinity	Feb 19. 2013	35	mg/L
			36	mg/L
			34	mg/L
			38	mg/L
O.Reg 399/07 Schedule 15.1	Alkalinity	Sept 3. 2013	35	mg/L
			34	mg/L
			36	mg/L
			32	mg/L

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony(Sb)	July 8, 2013	<0.0005	mg/L	NO
Arsenic(As)	July 8, 2013	<0.001	mg/L	NO
Barium(Ba)	July 8, 2013	0.02	mg/L	NO
Boron(B)	July 8, 2013	<0.01	mg/L	NO
Cadmium(Cd)	July 8, 2013	<0.0001	mg/L	NO
Chromium(Cr)	July 8, 2013	<0.001	mg/L	NO
*Lead(Pb)			mg/L	NO
Mercury(Hg)	July 8, 2013	<0.0001	mg/L	NO
Selenium(Se)	July 8, 2013	<0.001	mg/L	NO
Sodium(Na)	July 3, 2012	15	mg/L	NO
Uranium(U)	July 8, 2013	<0.001	mg/L	NO
Fluoride(F)	July 8, 2013	0.69	mg/L	NO
Nitrite : Embrun Marionville Russell	Oct 7, 2013	<0.10	mg/L	NO
	Oct 7, 2013	0.27	mg/L	NO
	Oct 7, 2013	<0.10	mg/L	NO
Nitrate: Embrun	Oct 7, 2013	0.17	mg/L	NO
	Oct 7, 2013	0.20	mg/L	NO

Marionville Russell	Oct 7, 2013	0.21	mg/L	NO
------------------------	-------------	------	------	----

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

### Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (mg/L) (min#) – (max #)	Number of Exceedances
Exempt			

### Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	July 8, 2013	<1.0	ug/L	NO
Aldicarb	July 8, 2013	<9	ug/L	NO
Aldrin + Dieldrin	July 8, 2013	<0.012	ug/L	NO
Atrazine + N-dealkylated metabolites	July 8, 2013	<0.2	ug/L	NO
Azinphos-methyl	July 8, 2013	<2	ug/L	NO
Bendiocarb	July 8, 2013	<2	ug/L	NO
Benzene	July 8, 2013	<0.5	ug/L	NO
Benzo(a)pyrene	July 8, 2013	<0.01	ug/L	NO
Bromoxynil	July 8, 2013	<0.5	ug/L	NO
Carbaryl	July 8, 2013	<5	ug/L	NO
Carbofuran	July 8, 2013	<5	ug/L	NO
Carbon Tetrachloride	July 8, 2013	<0.2	ug/L	NO
Chlordane (Total)	July 8, 2013	<0.006	ug/L	NO
Chlorpyrifos	July 8, 2013	<1	ug/L	NO
Cyanazine	July 8, 2013	<1	ug/L	NO
Diazinon	July 8, 2013	<1	ug/L	NO
Dicamba	July 8, 2013	<1	ug/L	NO
1,2-Dichlorobenzene	July 8, 2013	<0.4	ug/L	NO
1,4-Dichlorobenzene	July 8, 2013	1	ug/L	NO
Dichlorodiphenyltrichloroethane (DDT) + metabolites	July 8, 2013	<0.024	ug/L	NO
1,2-Dichloroethane	July 8, 2013	<0.2	ug/L	NO
1,1-Dichloroethylene (vinylidene chloride)	July 8, 2013	<0.5	ug/L	NO
Dichloromethane	July 8, 2013	<4.0	ug/L	NO
2-4 Dichlorophenol	July 8, 2013	<0.5	ug/L	NO
2,4-Dichlorophenoxy acetic acid (2,4-D)	July 8, 2013	<1	ug/L	NO

<b>Diclofop-methyl</b>	July 8, 2013	<1.0	ug/L	NO
<b>Dimethoate</b>	July 8, 2013	<2.5	ug/L	NO
<b>Dinoseb</b>	July 8, 2013	<1	ug/L	NO
<b>Diquat</b>	July 8, 2013	<5	ug/L	NO
<b>Diuron</b>	July 8, 2013	<10	ug/L	NO
<b>Glyphosate</b>	July 8, 2013	<10	ug/L	NO
<b>Heptachlor + Heptachlor Epoxide</b>	July 8, 2013	<0.012	ug/L	NO
<b>Lindane (Total)</b>	July 8, 2013	<0.006	ug/L	NO
<b>Malathion</b>	July 8, 2013	<5	ug/L	NO
<b>Methoxychlor</b>	July 8, 2013	<0.006	ug/L	NO
<b>Metolachlor</b>	July 8, 2013	<1.0	ug/L	NO
<b>Metribuzin</b>	July 8, 2013	<5	ug/L	NO
<b>Monochlorobenzene</b>	July 8, 2013	<0.2	ug/L	NO
<b>Paraquat</b>	July 8, 2013	<5	ug/L	NO
<b>Parathion</b>	July 8, 2013	<1	ug/L	NO
<b>Pentachlorophenol</b>	July 8, 2013	<0.5	ug/L	NO
<b>Phorate</b>	July 8, 2013	<1.0	ug/L	NO
<b>Picloram</b>	July 8, 2013	<5	ug/L	NO
<b>Polychlorinated Biphenyls(PCB)</b>	July 8, 2013	<0.1	ug/L	NO
<b>Prometryne</b>	July 8, 2013	<1.0	ug/L	NO
<b>Simazine</b>	July 8, 2013	<1	ug/L	NO
<b>THM</b> (NOTE: show latest annual average)				
<b>Embrun</b>	Oct 7, 2013	28.4	ug/L	NO
<b>Marionville</b>	Oct 7, 2013	27.8	ug/L	NO
<b>Russell</b>	Oct 7, 2013	27.5	ug/L	NO
<b>Temephos</b>	July 8, 2013	<10	ug/L	NO
<b>Terbufos</b>	July 8, 2013	<1.0	ug/L	NO
<b>Tetrachloroethylene</b>	July 8, 2013	<0.3	ug/L	NO
<b>2,3,4,6-Tetrachlorophenol</b>	July 8, 2013	<0.5	ug/L	NO
<b>Triallate</b>	July 8, 2013	<1	ug/L	NO
<b>Trichloroethylene</b>	July 8, 2013	<0.3	ug/L	NO
<b>2,4,6-Trichlorophenol</b>	July 8, 2013	<0.5	ug/L	NO
<b>2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)</b>	July 8, 2013	<1	ug/L	NO
<b>Trifluralin</b>	July 8, 2013	<1.0	ug/L	NO
<b>Vinyl Chloride</b>	July 8, 2013	<0.2	ug/L	NO

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Chloramine (combined)	Max Value: 2.77	mg/L	Jan - Dec

